

**OFFICE OF PUBLIC EDUCATION FACILITIES MODERNIZATION**

**WINDOW REPLACEMENT SERVICES  
RIVER TERRACE ELEMENTARY SCHOOL**

**Solicitation #: GM-09-S-0427-FM**

**Addendum No. 5  
Issued: May 15, 2009**

---

This Addendum Number 05 is issued by e-mail on May 15, 2009. Except as modified hereby, the Request for Proposals ("RFP") remains unmodified.

**Item #1**

**Clarifications:**

1. Please disregard the clarification issued by Addendum 4. Division 085113, Part 2.3, Subpart B 1 of the Specification should read as follows: "Performance Class and Grade: AW85 or higher."
2. Offerors proposing windows from manufacturers other than those listed in the Specifications must have those products approved for use by the Office prior to the bid date.

**Item #2**

The bid date remains unchanged. Proposals are due by **Tuesday, May 19, 2009 at 5 pm EDT**. Proposals that are hand-delivered should be delivered to OPEFM's new office space in RFK stadium, located through the Lot 4, Gate F entrance.

- End of Addendum No. 5 -